



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1783-CPR-865

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Cable Type : A/J-VQ(ZN)H(SR)H

Reaction to Fire Performance: Cca, s1a, d2, a1

(SCOPE IS AT THE ATTACHMENT)

placed on the market under the name or trade mark of

AT VE T KABLOLAMA SİSTEMLERİ SAN. VE TİC. A.Ş.
ARAPCAMI MAH. BANKALAR CAD. EKAS HAN 29 29A BEYOĞLU / İSTANBUL

and produced in the manufacturing plant

ERCIYES MAH.HES CAD.NO.22 P.K.245 38210 HACILAR-KAYSERİ/TÜRKİYE

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 50575: 2014 + A1: 2016

under system 1 + for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product .

This certificate was first issued on 17.08.2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, Rev. 0, 17.08.2018

Ali Fuat ÇOLAK
Deputy Director of Directives



www.tse.org.tr / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.
This certificate cannot be altered, partially duplicated or creased for misunderstanding.



TÜRK STANDARDLARI ENSTİTÜSÜ

TURKISH STANDARDS INSTITUTION

ATTACHMENT OF THE CERTIFICATE OF CONSTANCY OF PERFORMANCE

PRODUCT DESCRIPTION:

Designation of cable family	Fiberoptic // A/J-VQ(ZN)H(SR)H
Fiber count	2-12

RELEVANT CONSTRUCTIONAL INFORMATION:

Cable design	Tight Coated Fiber , Unfilled, Metallic Armoured, Double Jacket
Single Tube / Multitube	Multitube
Concentric shield	Does not include
Armour	Includes

ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE TS CLC TS 50576:

	Covered field
<input checked="" type="checkbox"/>	Armoured
<input type="checkbox"/>	Unarmoured multicore
<input type="checkbox"/>	Single core sheated
<input type="checkbox"/>	Single core unsheated
<input type="checkbox"/>	Cable family including diameter \leq 5mm



Attachment of the Certificate of Constancy of Performance, 1783-CPR-865.

www.tse.org.tr / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.
This certificate cannot be altered, partially duplicated or erased for misunderstanding.